

विश्वी गुरु विद्या



MUNICIPAL CORPORATION OF DELHI
NARELA ZONE, NARELA, DELHI-110040

SCHOOL HEALTH CERTIFICATE

D. NO. DHO/NRZ/2024/ **1539**

DATE: **20/03/24**

DATE OF INSPECTION : 20/03/2024

1. NAME OF SCHOOL : U.S.M. PUBLIC SCHOOL
2. ADDRESS : VEENA ENCLAVE, NANGLOI, DELHI-110041
3. NO. OF SHIFTS : ONE TIMING: 07:45 AM TO 02:00 PM

ACCOMMODATION PROVIDED:-

THE FLOOR AREA IN THE CLASSROOM IS SUFFICIENT.

THE CLASSES ARE WELL LIGHTED.

THE CLASSROOMS ARE WELL VENTILATED.

THE CLASSROOMS ARE KEPT NEAT AND CLEAN.

THE DRINKING WATER IS WATER TEST REPORT APPROVED BY DJB Lab..

THE TOILET ARRANGEMENT IS SANITARY & HYGIENIC AND SUFFICIENT IN NUMBER.

REMARKS: THIS CERTIFICATE DOES NOT INDICATES PERMISSIBILITY FROM LAND POINT OF VIEW.

The certificate is valid for a period of one year from the date of issue.

The MANAGER

U.S.M. PUBLIC SCHOOL PUBLIC SCHOOL
VEENA ENCLAVE, NANGLOI, DELHI-110041

Dr. Jyoti
20/03/24
DY. HEALTH OFFICER
NARELA ZONE



9/6
Date: 26/8/23

DELHI JAL BOARD
(GOVT. OF N.C.T. DELHI)

QUALITY CONTROL LABORATORY,
WATER TREATMENT PLANT NANGLOI, DELHI-110041

7/5
आज़ादी का
अमृत महोत्सव

Water sample collected from "U. S. M. Sr. Sec. Public School" Veena Enclave, Nr. Nangloi Railway Metro Station, Nangloi, New Delhi-110041 Vide Challan No.150 Dated: 01.02.2024.

S. No	Parameter	Units	Limit		S1
			Acceptable	Permissible	
PHYSICAL EXAMINATION					
1.	Date of collection	-----	--	--	21.02.2024
2.	Date of Analysis	-----	--	--	22.02.2024
3.	Colour	Hazen	5.0	15	Clear
4.	Odour	-----	No. Objectionable		No Obj.
5.	Turbidity	N.T.U.	1.0	5.0	1.25
6.	PH value	-----	6.5	8.5	7.4
7.	Electrical Conductivity	µmho	--	--	233
8.	Total dissolved solids	mg/l	500	2000	140
CHEMICAL EXAMINATION					
9.	p th Alkalinity	mg/l	--	--	NIL
10.	Total Alkalinity	mg/l	200	600	75
11.	Total Hardness	mg/l	200	600	86
12.	Calcium Hardness	mg/l	--	--	65
13.	Magnesium Hardness	mg/l	--	--	21
14.	Calcium as Ca	mg/l	75	200	26
15.	Magnesium as Mg	mg/l	30	100	5.04
16.	Ammonia as N	mg/l	0.5	N.R.	NIL
17.	Nitrite as N	mg/l	---	--	NIL
18.	Nitrate as NO ₃	mg/l	45	N.R.	01
19.	Sulphate	mg/l	200	400	28
20.	Chloride	mg/l	250	1000	15
21.	Dissolved Iron	mg/l	0.3	N.R.	0.02
22.	Fluoride	mg/l	1	1.5	0.02
23.	Cyanide	mg/l	0.05	N.R.	ND
24.	Residual Chlorine	mg/l	0.20	1.0	NIL
BACTERIOLOGICAL EXAMINATION					
25.	Coli-form per 100 ml at 37°C	MPN	0		0
REMARKS : As per tested parameter					

REMARKS: As per tested parameters sample -S1 can be use for drinking purpose.

Chemist

ACWA

APPROVED BY
DELHI JAL BOARD
General Manager
Quality Control Laboratory
Water Treatment Plant Nangloi